



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH
(e-mail: igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021-3691-92

Dated:- 28/12/2021

Subject: Fire NOC in favour of Govt. Higher Secondary School Paskum, Kargil.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Kargil. The detailed report is as under:

Location/ Accessibility:

The School is constructed at Paskum, Kargil. It is located at Longitude 76.194132 and Latitude 34.510255. The site is approximately 08 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 16 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The school building have four blocks and the detail of the blocks are as under:

1st block: It is three storied school building having one stair case. In the ground floor there are mid-day meal, 2 no's store rooms and 3 class rooms. There are two windows in each room. The size of the window is 6x3 feet and the two sides of window have provision to open. 1st floor have Principal office, staff room, office and three class rooms. 2nd floor have exam hall, I.C.T lab and two class rooms.

2nd block: It is single storied building having library and two bathrooms. There are two windows in each room and the size is 3x4 feet. Two sides of window have provision to open.

3rd block: It is single storied building having physics, chemistry, zoology and botany laboratory. There are two windows in each room and the size is 7x5 feet. Two sides of window have provision to open.


4th block: It is single storied building having one room being used for chowkidar residence.

The following Fire Safety equipment's found installed in School Building:

- 1.04 no's of fire extinguishers ABC Type 6 kg capacity installed in the school building.
1. 02 no's of sand buckets installed in the school premises.
2. 04 no's of plastic water tanks 1000 litres capacity at over head of the building.
3. One submersible bore connected with high rated pump.

There is a mandatory requirement for keeping 2 exit stair cases in first 3 blocks of the school building each having at least 1.5 meter width besides constructing 20 thousand litres of underground water tank in school premises along with placement of 7 no of ABC type 6 Kg capacity fire extinguishers in the school.

A **provisional FIRE NOC for a period of 6 months** is given to **Govt. Higher Secondary School Paskum, Kargil** from the date of issuance of this letter and the school management is advised to fulfilling the above listed fire safety requirements in shortest possible time.


Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

1. Principal, Govt. Higher Secondary School Paskum, Kargil for info
2. Superintendent of Police, F&ES, Ladakh for information and n/a