



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888)

No: FB&ES/ Dir/NOC/2023-072-94

Dated: 07/06/2023.

Subject: Fire NOC in favour of Govt. Higher Secondary School Paskum, Kargil.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the school which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The school is constructed at Paskum, Kargil. It is located at Longitude 76.194132 and Latitude 34.510255. The site is approximately 08 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 16 minutes to reach the site and is not approachable for fire appliances.

Detail of building:

The school building has four blocks and the detail of the block are as under:

1st block: It is three stored school building having two stair case. In the ground floor there are mid-day mail, 2 no's store rooms and 3 class rooms. There are two windows in each room. The size of the window is 6x3 feet and the two side of window have provision to open. 1st floor has Principal office, staff room, office and three class room. 2nd floor has exam hall, I.C.T lab and two class rooms.

2nd block: It is single stories building having library and two bathrooms. There are two windows in each room and the size is 3x4 feet. Two side of window have provision to open.

3rd block: It is single stories building have physic laboratory, chemistry laboratory, Zoology laboratory and botany laboratory. There are two windows in each room and the size is 7x5 feet. Two side of window have provision to open.

4th block: It is single stories building having one room use for chokidar residence.

There are 203 students and 35 staffs

The following Fire Safety equipment's which are installed in School Building:

01. 04 number of fire extinguisher ABC Type 6 kg capacity is installed in the school building.
02. 02 number of sand bucket is installed in the school premises.
03. 04 number of plastic water tank 1000 liters capacity over head of the building.
04. 20 thousand liters underground reserve water tank shall be made in the school premises.
05. One submersible bore connected with high rated pump.

FIRE NOC is given in favour of Govt. Higher Secondary School Paskum, Kargil for period of One year from the issuance of this letter.

Director, FB&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

01. Principal, Govt. Higher Secondary School Paskum, Kargil for information and n/a.
02. Superintendent of Police, FB&ES, Ladakh for information.
03. Office file.